

Maintenance Checklist

for contractors

Vitocell 300-W, Vitocell 300-V
Type EVIA-A, EVIB-A+, EVIB-A

Safety instructions



Please follow these safety instructions closely to prevent accidents and material losses.

Installation, commissioning, inspection, maintenance and repairs must only be carried out by a competent person (heating engineer/installation contractor). For heat pumps: work on the refrigerant circuit may only be carried out by authorised refrigeration engineers.


Before working on the appliance/heating system, isolate it from the power supply (e.g. by removing a separate mains fuse or by means of a mains isolator) and safeguard against unauthorised reconnection.

When using gas as fuel, also close the main gas shut-off valve and safeguard against unauthorised reopening.

Check for gas tightness after installation.

Maintenance work on parts that fulfil a safety function is not permitted. For replacements, use only original spare parts supplied or approved by Viessmann. Install the components with new gaskets.

Finding wearing parts



The wearing parts that have to be serviced can be identified and ordered via the Viessmann spare part app.

Steps to be followed

Step	Completed
1. Shutting down the system	<input type="checkbox"/>
2. Checking the safety valve function	<input type="checkbox"/>
3. Cleaning the inside of the DHW cylinder	<input type="checkbox"/>
4. Reassembling the DHW cylinder	<input type="checkbox"/>
5. Checking the connections on the water side for tightness	<input type="checkbox"/>

Viessmann Climate Solutions SE
35108 Allendorf
Telephone: +49 6452 70-0
Fax: +49 6452 70-2780
www.viessmann.com

Viessmann Limited
Hortonwood 30, Telford
Shropshire, TF1 7YP, GB
Telephone: +44 1952 675000
Fax: +44 1952 675040
E-mail: info-uk@viessmann.com