

Maintenance Checklist

for contractors



Vitocal 200-G

Type BWC 201.A06, BWC 201.A08, BWC 201.A10, BWC 201.A17,
BWC 201.A13, BWC-M 201.A06, BWC-M 201.A08, BWC-M 201.A10

Safety instructions



Please follow these safety instructions closely to prevent accidents and material losses.


Installation, commissioning, inspection, maintenance and repairs must only be carried out by a competent person (heating engineer/installation contractor). For heat pumps: work on the refrigerant circuit may only be carried out by authorised refrigeration engineers.

Before working on the appliance/heating system, isolate it from the power supply (e.g. by removing a separate mains fuse or by means of a mains isolator) and safeguard against unauthorised reconnection.

When using gas as fuel, also close the main gas shut-off valve and safeguard against unauthorised reopening. Check for gas tightness after installation.

Maintenance work on parts that fulfil a safety function is not permitted. For replacements, use only original spare parts supplied or approved by Viessmann. Install the components with new gaskets.

Finding wearing parts



The wearing parts that have to be serviced can be identified and ordered via the Viessmann spare part app.

Steps to be followed

Step	Completed
1. Opening the heat pump	<input type="checkbox"/>
2. Checking the refrigerant circuit for leaks	<input type="checkbox"/>
3. Checking the expansion vessels and primary circuit/heating circuit pressure	<input type="checkbox"/>
4. Checking the electrical connections for firm seating	<input type="checkbox"/>
5. Closing the heat pump	<input type="checkbox"/>
6. Checking the heat pump for noise	<input type="checkbox"/>
7. Checking the system function	<input type="checkbox"/>

Viessmann Werke GmbH & Co. KG
D-35107 Allendorf
Telephone: +49 6452 70-0
Fax: +49 6452 70-2780
www.viessmann.com

Viessmann Limited
Hortonwood 30, Telford
Shropshire, TF1 7YP, GB
Telephone: +44 1952 675000
Fax: +44 1952 675040
E-mail: info-uk@viessmann.com