

for contractors

Vitoplanar connection set 5 m/10 m

For Vitoplanar EF2/EF3

Safety instructions



Please follow these safety instructions closely to prevent accidents and material losses.

Installation, commissioning, inspection, maintenance and repairs must only be carried out by a competent person (heating engineer/installation contractor).

Before working on the equipment/heating system, isolate the power supply (e.g. by removing a separate mains fuse or by means of a main isolator) and safeguard against unauthorised reconnection. Repairing components that fulfil a safety function can compromise the safe operation of your heating system. For replacements, use only original spare parts supplied or approved by Viessmann.

Before installation

Standard delivery

- Connecting cable, 5 m or 10 m
- 1 heat shrink tube, length 200 mm
- 2 heat shrink tubes, length 45 mm
- 2 butt connectors, non-insulated, 1.0 mm²
- 1 butt connector, non-insulated, 1.5 mm²



Required tools

- Wire stripper
- Crimping pliers
- Wire cutters
- Heat gun

Connecting the cables





- Strip the outer sheath with the wire stripper (approx. 150 mm). Cut the cores to staggered lengths with the wire cutters. Strip the cores with the wire stripper (approx. 5 mm). Squeeze the butt connector (1.0 mm²) onto the cores of one connecting cable with the crimping pliers.
- Slide on 2 heat shrink tubes (length 45 mm). Squeeze the butt connector (1.0 mm²) onto the cores of the other connecting cable with the crimping pliers.







- **3.** Connect the protective braid/earthing to the butt connector (1.5 mm²) (crimp with the crimping pliers).
- Slide the heat shrink tubes onto the butt connectors and shrink with the heat gun.
- Slide on the heat shrink tube (length 200 mm) and shrink with the heat gun.

Viessmann Werke GmbH & Co. KG D-35107 Allendorf Telephone: +49 6452 70-0 Fax: +49 6452 70-2780 www.viessmann.com



Viessmann Limited Hortonwood 30, Telford Shropshire, TF1 7YP, GB Telephone: +44 1952 675000 Fax: +44 1952 675040 E-mail: info-uk@viessmann.com